

GENERATOR RUNTIME, GAS USE AND HEAT RECOVERY SUMMARY

Ten West 66th St. Corp.

11/01/05 to 11/30/05

Date	Good Data (%)	Total Generator Runtime (hrs)	Other Facility Gas Use (cu ft)	Total Generator Gas Use (cu ft)	Total Useful Heat Recovery (MBtu)	Total Unused Heat Recovery (MBtu)	Percent Useful Heat Recovery (%)
11/01/05	0.00	-	n/a	-	-	n/a	n/a
11/02/05	0.00	-	n/a	-	-	n/a	n/a
11/03/05	0.00	-	n/a	-	-	n/a	n/a
11/04/05	0.00	-	n/a	-	-	n/a	n/a
11/05/05	0.00	-	n/a	-	-	n/a	n/a
11/06/05	0.00	-	n/a	-	-	n/a	n/a
11/07/05	0.00	-	n/a	-	-	n/a	n/a
11/08/05	0.00	-	n/a	-	-	n/a	n/a
11/09/05	0.00	-	n/a	-	-	n/a	n/a
11/10/05	0.00	-	n/a	-	-	n/a	n/a
11/11/05	0.00	-	n/a	-	-	n/a	n/a
11/12/05	0.00	-	n/a	-	-	n/a	n/a
11/13/05	0.00	-	n/a	-	-	n/a	n/a
11/14/05	0.00	-	n/a	-	-	n/a	n/a
11/15/05	0.00	-	n/a	-	-	n/a	n/a
11/16/05	0.00	-	n/a	-	-	n/a	n/a
11/17/05	0.00	-	n/a	-	-	n/a	n/a
11/18/05	99.31	24.00	n/a	21270.00	7382.69	n/a	n/a
11/19/05	100.00	23.06	n/a	21170.00	7655.19	n/a	n/a
11/20/05	100.00	18.01	n/a	16290.00	5772.90	n/a	n/a
11/21/05	98.96	0.00	n/a	0.00	0.00	n/a	n/a
11/22/05	97.92	11.77	n/a	10640.00	120.44	n/a	n/a
11/23/05	99.65	24.00	n/a	22040.00	3869.47	n/a	n/a
11/24/05	99.65	23.51	n/a	21630.00	7226.30	n/a	n/a
11/25/05	100.00	24.00	n/a	22250.00	7239.27	n/a	n/a
11/26/05	100.00	22.51	n/a	21010.00	7028.35	n/a	n/a
11/27/05	98.61	0.00	n/a	0.00	0.00	n/a	n/a
11/28/05	97.92	13.51	n/a	11910.00	123.48	n/a	n/a
11/29/05	99.31	24.00	n/a	21070.00	4066.78	n/a	n/a
11/30/05	99.31	21.86	n/a	20400.00	7260.41	n/a	n/a
Total	43.02	230.23	n/a	209680.00	57745.28	n/a	n/a

Generator Gas Use



