

GENERATOR RUNTIME, GAS USE AND HEAT RECOVERY SUMMARYTen West 66th St. Corp.
12/01/05 to 12/31/05

Date	Good Data (%)	Total Generator Runtime (hrs)	Other Facility Gas Use (cu ft)	Total Generator Gas Use (cu ft)	Total Useful Heat Recovery (MBtu)	Total Unused Heat Recovery (MBtu)	Percent Useful Heat Recovery (%)
12/01/05	98.96	17.27	n/a	15730.00	5151.99	n/a	n/a
12/02/05	100.00	20.00	n/a	21350.00	7631.17	n/a	n/a
12/03/05	100.00	24.00	n/a	21950.00	7574.63	n/a	n/a
12/04/05	100.00	24.00	n/a	22090.00	7469.89	n/a	n/a
12/05/05	100.00	24.00	n/a	22180.00	7588.24	n/a	n/a
12/06/05	98.96	17.03	n/a	16350.00	5488.24	n/a	n/a
12/07/05	100.00	24.00	n/a	22580.00	7335.39	n/a	n/a
12/08/05	100.00	24.00	n/a	22440.00	7632.45	n/a	n/a
12/09/05	100.00	24.00	n/a	22730.00	7822.87	n/a	n/a
12/10/05	100.00	24.00	n/a	22740.00	7797.25	n/a	n/a
12/11/05	98.61	16.03	n/a	15410.00	4872.20	n/a	n/a
12/12/05	100.00	24.00	n/a	22680.00	7537.80	n/a	n/a
12/13/05	100.00	24.00	n/a	22650.00	7851.70	n/a	n/a
12/14/05	100.00	24.00	n/a	22790.00	7788.12	n/a	n/a
12/15/05	100.00	24.00	n/a	22790.00	7672.49	n/a	n/a
12/16/05	100.00	24.00	n/a	22480.00	7691.38	n/a	n/a
12/17/05	100.00	24.00	n/a	22450.00	7856.66	n/a	n/a
12/18/05	100.00	24.00	n/a	22250.00	7592.89	n/a	n/a
12/19/05	100.00	24.00	n/a	22370.00	7869.64	n/a	n/a
12/20/05	100.00	24.00	n/a	22730.00	7647.34	n/a	n/a
12/21/05	100.00	24.00	n/a	22970.00	7645.42	n/a	n/a
12/22/05	100.00	24.00	n/a	22960.00	7801.57	n/a	n/a
12/23/05	100.00	22.26	n/a	21590.00	7452.59	n/a	n/a
12/24/05	96.53	0.00	n/a	0.00	0.00	n/a	n/a
12/25/05	96.53	13.75	n/a	12790.00	155.67	n/a	n/a
12/26/05	96.53	24.00	n/a	22010.00	0.00	n/a	n/a
12/27/05	96.88	23.30	n/a	21920.00	0.00	n/a	n/a
12/28/05	96.88	24.00	n/a	21920.00	0.00	n/a	n/a
12/29/05	96.88	23.77	n/a	21570.00	0.00	n/a	n/a
12/30/05	97.22	22.83	n/a	21580.00	0.00	n/a	n/a
12/31/05	96.88	23.77	n/a	21690.00	0.00	n/a	n/a
Total	99.06	679.99	n/a	639740.00	168927.58	n/a	n/a

Generator Gas Use



