

GENERATOR RUNTIME, GAS USE AND HEAT RECOVERY SUMMARY

Ten West 66th St. Corp.

06/01/06 to 06/30/06

Date	Good Data (%)	Total Generator Runtime (hrs)	Other Facility Gas Use (cu ft)	Total Generator Gas Use (cu ft)	Total Useful Heat Recovery (MBtu)	Total Unused Heat Recovery (MBtu)	Percent Useful Heat Recovery (%)
06/01/06	100.00	1.35	n/a	22400.00	5288.28	n/a	n/a
06/02/06	100.00	1.34	n/a	22200.00	5326.71	n/a	n/a
06/03/06	100.00	1.37	n/a	22300.00	5408.39	n/a	n/a
06/04/06	100.00	1.39	n/a	22400.00	5403.59	n/a	n/a
06/05/06	100.00	1.40	n/a	22500.00	5419.60	n/a	n/a
06/06/06	100.00	1.41	n/a	23000.00	5445.23	n/a	n/a
06/07/06	100.00	1.42	n/a	22900.00	5499.68	n/a	n/a
06/08/06	100.00	1.44	n/a	23300.00	5563.74	n/a	n/a
06/09/06	100.00	1.45	n/a	22800.00	5565.34	n/a	n/a
06/10/06	100.00	2.16	n/a	23200.00	5629.40	n/a	n/a
06/11/06	100.00	5.70	n/a	23100.00	5669.44	n/a	n/a
06/12/06	98.61	3.98	n/a	35500.00	5309.10	n/a	n/a
06/13/06	100.00	2.64	n/a	50800.00	5614.99	n/a	n/a
06/14/06	100.00	1.44	n/a	50500.00	5530.11	n/a	n/a
06/15/06	96.18	0.81	n/a	29700.00	3199.87	n/a	n/a
06/16/06	91.32	0.00	n/a	300.00	0.00	n/a	n/a
06/17/06	91.67	0.00	n/a	200.00	0.00	n/a	n/a
06/18/06	91.32	0.00	n/a	200.00	0.00	n/a	n/a
06/19/06	91.67	0.00	n/a	300.00	0.00	n/a	n/a
06/20/06	91.67	0.00	n/a	200.00	0.00	n/a	n/a
06/21/06	91.67	0.00	n/a	300.00	0.00	n/a	n/a
06/22/06	92.01	0.00	n/a	300.00	0.00	n/a	n/a
06/23/06	91.67	0.00	n/a	200.00	0.00	n/a	n/a
06/24/06	92.01	0.00	n/a	200.00	0.00	n/a	n/a
06/25/06	92.01	0.00	n/a	200.00	0.00	n/a	n/a
06/26/06	92.01	0.00	n/a	200.00	0.00	n/a	n/a
06/27/06	93.75	1.34	n/a	6300.00	1542.28	n/a	n/a
06/28/06	96.53	0.75	n/a	12300.00	2938.82	n/a	n/a
06/29/06	92.01	0.00	n/a	200.00	0.00	n/a	n/a
06/30/06	92.36	0.00	n/a	200.00	0.00	n/a	n/a
Total	95.95	31.39	n/a	438200.00	84354.59	n/a	n/a

