

GENERATOR RUNTIME, GAS USE AND HEAT RECOVERY SUMMARY

Ten West 66th St. Corp.

04/01/07 to 04/30/07

Date	Good Data (%)	Total Generator Runtime (hrs)	Other Facility Gas Use (cu ft)	Total Generator Gas Use (cu ft)	Total Useful Heat Recovery (MBtu)	Total Unused Heat Recovery (MBtu)	Percent Useful Heat Recovery (%)
04/01/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/02/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/03/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/04/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/05/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/06/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/07/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/08/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/09/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/10/07	100.00	0.00	n/a	10.00	0.00	n/a	n/a
04/11/07	98.96	6.53	n/a	5990.00	0.00	n/a	n/a
04/12/07	99.65	0.76	n/a	990.00	0.00	n/a	n/a
04/13/07	100.00	0.00	n/a	10.00	0.00	n/a	n/a
04/14/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/15/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/16/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/17/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/18/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/19/07	99.31	0.02	n/a	120.00	0.00	n/a	n/a
04/20/07	99.31	7.07	n/a	7280.00	0.00	n/a	n/a
04/21/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/22/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/23/07	99.31	10.99	n/a	11570.00	0.00	n/a	n/a
04/24/07	100.00	21.42	n/a	19660.00	0.00	n/a	n/a
04/25/07	98.96	22.54	n/a	19920.00	0.00	n/a	n/a
04/26/07	100.00	24.00	n/a	21290.00	0.00	n/a	n/a
04/27/07	100.00	24.00	n/a	21680.00	0.00	n/a	n/a
04/28/07	100.00	19.26	n/a	17010.00	0.00	n/a	n/a
04/29/07	100.00	0.00	n/a	0.00	0.00	n/a	n/a
04/30/07	99.65	9.68	n/a	13070.00	0.00	n/a	n/a
Total	99.84	146.28	n/a	138600.00	0.00	n/a	n/a

Generator Gas Use



Total Useful Heat Recovery

