


GENERATOR RUNTIME, GAS USE AND HEAT RECOVERY SUMMARY

Ten West 66th St. Corp.

01/01/07 to 12/31/07

Date	Good Data (%)	Total Generator Runtime (hrs)	Other Facility Gas Use (cu ft)	Total Generator Gas Use (cu ft)	Total Useful Heat Recovery (MBtu)	Total Unused Heat Recovery (MBtu)	Percent Useful Heat Recovery (%)
Jan 2007	99.80	629.14	n/a	535680.00	0.00	n/a	n/a
Feb 2007	99.94	489.17	n/a	451080.00	0.00	n/a	n/a
Mar 2007	99.59	19.34	n/a	16650.00	0.00	n/a	n/a
Apr 2007	99.84	146.28	n/a	138600.00	0.00	n/a	n/a
May 2007	99.90	75.75	n/a	115420.00	0.00	n/a	n/a
Jun 2007	99.94	199.45	n/a	368260.00	0.00	n/a	n/a
Jul 2007	99.89	37.49	n/a	318170.00	0.00	n/a	n/a
Aug 2007	96.56	107.20	n/a	419190.00	0.00	n/a	n/a
Sep 2007	99.68	57.61	n/a	371670.00	0.00	n/a	n/a
Oct 2007	99.96	285.27	n/a	601450.00	0.00	n/a	n/a
Nov 2007	97.43	568.52	n/a	457710.00	0.00	n/a	n/a
Dec 2007	66.67	414.33	n/a	-	0.00	n/a	n/a
Total	96.54	3029.55	n/a	3793880.00	0.00	n/a	n/a

Generator Gas Use



Total Useful Heat Recovery

