

GENERATOR RUNTIME, GAS USE AND HEAT RECOVERY SUMMARY

Ten West 66th St. Corp.

06/01/08 to 06/30/08

Date	Good Data (%)	Total Generator Runtime (hrs)	Other Facility Gas Use (cu ft)	Total Generator Gas Use (cu ft)	Total Useful Heat Recovery (MBtu)	Total Unused Heat Recovery (MBtu)	Percent Useful Heat Recovery (%)
06/01/08	100.00	1.08	n/a	15850.00	0.00	n/a	n/a
06/02/08	100.00	1.09	n/a	15900.00	0.00	n/a	n/a
06/03/08	100.00	1.07	n/a	15660.00	0.00	n/a	n/a
06/04/08	100.00	1.15	n/a	16510.00	0.00	n/a	n/a
06/05/08	100.00	1.14	n/a	16410.00	0.00	n/a	n/a
06/06/08	100.00	1.17	n/a	16510.00	0.00	n/a	n/a
06/07/08	100.00	0.23	n/a	3690.00	0.00	n/a	n/a
06/08/08	99.65	0.59	n/a	8790.00	0.00	n/a	n/a
06/09/08	100.00	0.00	n/a	0.00	0.00	n/a	n/a
06/10/08	99.31	0.78	n/a	11590.00	0.00	n/a	n/a
06/11/08	100.00	1.04	n/a	15560.00	0.00	n/a	n/a
06/12/08	100.00	0.09	n/a	1480.00	0.00	n/a	n/a
06/13/08	98.96	0.82	n/a	8050.00	0.00	n/a	n/a
06/14/08	100.00	0.00	n/a	160.00	0.00	n/a	n/a
06/15/08	100.00	0.00	n/a	0.00	0.00	n/a	n/a
06/16/08	98.61	0.85	n/a	12100.00	0.00	n/a	n/a
06/17/08	100.00	1.07	n/a	15900.00	0.00	n/a	n/a
06/18/08	100.00	1.09	n/a	16110.00	0.00	n/a	n/a
06/19/08	100.00	1.08	n/a	16020.00	0.00	n/a	n/a
06/20/08	100.00	1.05	n/a	15640.00	0.00	n/a	n/a
06/21/08	100.00	1.04	n/a	15580.00	0.00	n/a	n/a
06/22/08	100.00	1.04	n/a	15530.00	0.00	n/a	n/a
06/23/08	100.00	1.02	n/a	15430.00	0.00	n/a	n/a
06/24/08	100.00	1.02	n/a	15460.00	0.00	n/a	n/a
06/25/08	100.00	1.02	n/a	15440.00	0.00	n/a	n/a
06/26/08	99.31	1.13	n/a	10280.00	0.00	n/a	n/a
06/27/08	100.00	0.00	n/a	0.00	0.00	n/a	n/a
06/28/08	100.00	0.00	n/a	0.00	0.00	n/a	n/a
06/29/08	100.00	0.00	n/a	0.00	0.00	n/a	n/a
06/30/08	100.00	0.00	n/a	0.00	0.00	n/a	n/a
Total	99.86	21.66	n/a	309650.00	0.00	n/a	n/a

Total Useful Heat Recovery

