


GENERATOR RUNTIME, GAS USE AND HEAT RECOVERY SUMMARY

Ten West 66th St. Corp.

01/01/08 to 12/31/08

Date	Good Data (%)	Total Generator Runtime (hrs)	Other Facility Gas Use (cu ft)	Total Generator Gas Use (cu ft)	Total Useful Heat Recovery (MBtu)	Total Unused Heat Recovery (MBtu)	Percent Useful Heat Recovery (%)
Jan 2008	82.18	384.70	n/a	287650.00	0.00	n/a	n/a
Feb 2008	93.02	271.12	n/a	247360.00	0.00	n/a	n/a
Mar 2008	99.99	713.74	n/a	629540.00	0.00	n/a	n/a
Apr 2008	99.88	225.49	n/a	549900.00	0.00	n/a	n/a
May 2008	99.55	37.28	n/a	508180.00	0.00	n/a	n/a
Jun 2008	99.86	21.66	n/a	309650.00	0.00	n/a	n/a
Jul 2008	99.69	16.49	n/a	244830.00	0.00	n/a	n/a
Aug 2008	99.73	22.70	n/a	197860.00	0.00	n/a	n/a
Sep 2008	99.95	11.78	n/a	9400.00	0.00	n/a	n/a
Oct 2008	99.81	89.56	n/a	80300.00	0.00	n/a	n/a
Nov 2008	100.00	0.00	n/a	0.00	0.00	n/a	n/a
Dec 2008	100.00	0.00	n/a	0.00	0.00	n/a	n/a
Total	97.81	1794.51	n/a	3064670.00	0.00	n/a	n/a

Generator Gas Use



Total Useful Heat Recovery

