

GENERATOR POWER QUALITY - DATA SUMMARY

Ten West 66th St. Corp.

07/01/07 to 07/31/07

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	0.01	54.16	93.95	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	0.6	51.5	57.1
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a


GENERATOR POWER QUALITY - DATA SUMMARY

Ten West 66th St. Corp.

07/01/07 to 07/31/07

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
07/01/07	100.00	n/a	n/a	0.00	n/a
07/02/07	100.00	n/a	n/a	0.00	n/a
07/03/07	100.00	n/a	n/a	0.00	n/a
07/04/07	100.00	n/a	n/a	0.00	n/a
07/05/07	100.00	n/a	n/a	0.00	n/a
07/06/07	100.00	n/a	n/a	0.00	n/a
07/07/07	100.00	n/a	n/a	0.00	n/a
07/08/07	100.00	n/a	n/a	0.00	n/a
07/09/07	100.00	n/a	n/a	705.84	n/a
07/10/07	100.00	n/a	n/a	1197.09	n/a
07/11/07	100.00	n/a	n/a	1214.90	n/a
07/12/07	100.00	n/a	n/a	208.41	n/a
07/13/07	100.00	n/a	n/a	0.00	n/a
07/14/07	100.00	n/a	n/a	0.00	n/a
07/15/07	100.00	n/a	n/a	0.00	n/a
07/16/07	100.00	n/a	n/a	776.91	n/a
07/17/07	100.00	n/a	n/a	1243.89	n/a
07/18/07	100.00	n/a	n/a	1245.86	n/a
07/19/07	100.00	n/a	n/a	1109.70	n/a
07/20/07	100.00	n/a	n/a	1235.08	n/a
07/21/07	100.00	n/a	n/a	1256.99	n/a
07/22/07	100.00	n/a	n/a	767.49	n/a
07/23/07	100.00	n/a	n/a	1300.17	n/a
07/24/07	100.00	n/a	n/a	1302.23	n/a
07/25/07	100.00	n/a	n/a	1264.29	n/a
07/26/07	100.00	n/a	n/a	1247.00	n/a
07/27/07	100.00	n/a	n/a	1233.81	n/a
07/28/07	100.00	n/a	n/a	99.49	n/a
07/29/07	100.00	n/a	n/a	817.42	n/a
07/30/07	100.00	n/a	n/a	994.27	n/a
07/31/07	100.00	n/a	n/a	1201.61	n/a
Total	100.00	n/a	n/a	20422.44	n/a

Generator Output Power



Generator Output Current

