

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

09/01/06 to 09/30/06

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	4.1	59.8	88.6
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

09/01/06 to 09/30/06

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
09/01/06	98.96	n/a	n/a	1596.00	n/a
09/02/06	0.00	n/a	n/a	-	n/a
09/03/06	0.00	n/a	n/a	-	n/a
09/04/06	21.88	n/a	n/a	336.30	n/a
09/05/06	100.00	n/a	n/a	1579.40	n/a
09/06/06	50.00	n/a	n/a	654.20	n/a
09/07/06	100.00	n/a	n/a	1572.60	n/a
09/08/06	100.00	n/a	n/a	1572.20	n/a
09/09/06	100.00	n/a	n/a	1562.10	n/a
09/10/06	100.00	n/a	n/a	1574.80	n/a
09/11/06	100.00	n/a	n/a	1601.20	n/a
09/12/06	39.58	n/a	n/a	538.90	n/a
09/13/06	0.00	n/a	n/a	-	n/a
09/14/06	0.00	n/a	n/a	-	n/a
09/15/06	0.00	n/a	n/a	-	n/a
09/16/06	4.17	n/a	n/a	35.40	n/a
09/17/06	100.00	n/a	n/a	1557.70	n/a
09/18/06	100.00	n/a	n/a	1553.00	n/a
09/19/06	100.00	n/a	n/a	1533.10	n/a
09/20/06	100.00	n/a	n/a	1546.00	n/a
09/21/06	34.38	n/a	n/a	426.40	n/a
09/22/06	0.00	n/a	n/a	-	n/a
09/23/06	0.00	n/a	n/a	-	n/a
09/24/06	66.67	n/a	n/a	472.80	n/a
09/25/06	73.96	n/a	n/a	580.70	n/a
09/26/06	32.29	n/a	n/a	383.60	n/a
09/27/06	100.00	n/a	n/a	1565.70	n/a
09/28/06	92.71	n/a	n/a	1095.30	n/a
09/29/06	35.42	n/a	n/a	218.10	n/a
09/30/06	28.13	n/a	n/a	0.00	n/a
Total	55.94	n/a	n/a	23555.49	n/a

Generator Output Power

