

## GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

06/01/07 to 06/30/07

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	25.8	52.3	89.2
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

## GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

06/01/07 to 06/30/07

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
06/01/07	100.00	n/a	n/a	1613.00	n/a
06/02/07	100.00	n/a	n/a	889.00	n/a
06/03/07	100.00	n/a	n/a	843.00	n/a
06/04/07	100.00	n/a	n/a	1465.00	n/a
06/05/07	100.00	n/a	n/a	1633.00	n/a
06/06/07	100.00	n/a	n/a	1586.00	n/a
06/07/07	100.00	n/a	n/a	1596.00	n/a
06/08/07	100.00	n/a	n/a	1570.00	n/a
06/09/07	100.00	n/a	n/a	916.00	n/a
06/10/07	100.00	n/a	n/a	846.00	n/a
06/11/07	100.00	n/a	n/a	1552.00	n/a
06/12/07	100.00	n/a	n/a	906.00	n/a
06/13/07	100.00	n/a	n/a	1566.00	n/a
06/14/07	100.00	n/a	n/a	1611.00	n/a
06/15/07	100.00	n/a	n/a	1600.00	n/a
06/16/07	100.00	n/a	n/a	893.00	n/a
06/17/07	100.00	n/a	n/a	817.00	n/a
06/18/07	100.00	n/a	n/a	1504.00	n/a
06/19/07	100.00	n/a	n/a	1519.00	n/a
06/20/07	100.00	n/a	n/a	1522.00	n/a
06/21/07	100.00	n/a	n/a	1236.00	n/a
06/22/07	100.00	n/a	n/a	1302.00	n/a
06/23/07	100.00	n/a	n/a	979.00	n/a
06/24/07	100.00	n/a	n/a	829.00	n/a
06/25/07	100.00	n/a	n/a	1511.00	n/a
06/26/07	100.00	n/a	n/a	1488.00	n/a
06/27/07	100.00	n/a	n/a	1130.00	n/a
06/28/07	100.00	n/a	n/a	895.00	n/a
06/29/07	100.00	n/a	n/a	905.00	n/a
06/30/07	100.00	n/a	n/a	905.00	n/a
Total	100.00	n/a	n/a	37627.00	n/a

# Generator Output Power

