

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

08/01/07 to 08/31/07

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	1.5	25.6	47.0
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

08/01/07 to 08/31/07

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
08/01/07	51.04	n/a	n/a	25.00	n/a
08/02/07	50.00	n/a	n/a	7.00	n/a
08/03/07	50.00	n/a	n/a	0.00	n/a
08/04/07	50.00	n/a	n/a	0.00	n/a
08/05/07	48.96	n/a	n/a	0.00	n/a
08/06/07	51.04	n/a	n/a	6.00	n/a
08/07/07	50.00	n/a	n/a	0.00	n/a
08/08/07	50.00	n/a	n/a	0.00	n/a
08/09/07	48.96	n/a	n/a	0.00	n/a
08/10/07	50.00	n/a	n/a	0.00	n/a
08/11/07	48.96	n/a	n/a	0.00	n/a
08/12/07	50.00	n/a	n/a	0.00	n/a
08/13/07	68.75	n/a	n/a	365.00	n/a
08/14/07	89.58	n/a	n/a	820.00	n/a
08/15/07	70.83	n/a	n/a	492.00	n/a
08/16/07	83.33	n/a	n/a	680.00	n/a
08/17/07	86.46	n/a	n/a	736.00	n/a
08/18/07	100.00	n/a	n/a	977.00	n/a
08/19/07	50.00	n/a	n/a	151.00	n/a
08/20/07	83.33	n/a	n/a	702.00	n/a
08/21/07	100.00	n/a	n/a	994.00	n/a
08/22/07	100.00	n/a	n/a	991.00	n/a
08/23/07	100.00	n/a	n/a	982.00	n/a
08/24/07	100.00	n/a	n/a	969.00	n/a
08/25/07	44.79	n/a	n/a	78.00	n/a
08/26/07	40.63	n/a	n/a	0.00	n/a
08/27/07	84.38	n/a	n/a	694.00	n/a
08/28/07	100.00	n/a	n/a	970.00	n/a
08/29/07	93.75	n/a	n/a	871.00	n/a
08/30/07	83.33	n/a	n/a	719.00	n/a
08/31/07	3.13	n/a	n/a	31.00	n/a
Total	67.14	n/a	n/a	12260.00	n/a

Generator Output Power

