

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

11/01/07 to 11/30/07

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	30.8	41.7	48.5
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

11/01/07 to 11/30/07

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
11/01/07	100.00	n/a	n/a	994.50	n/a
11/02/07	100.00	n/a	n/a	1013.50	n/a
11/03/07	100.00	n/a	n/a	997.00	n/a
11/04/07	100.00	n/a	n/a	991.00	n/a
11/05/07	100.00	n/a	n/a	993.00	n/a
11/06/07	100.00	n/a	n/a	990.00	n/a
11/07/07	100.00	n/a	n/a	1006.00	n/a
11/08/07	100.00	n/a	n/a	1014.00	n/a
11/09/07	100.00	n/a	n/a	1008.09	n/a
11/10/07	100.00	n/a	n/a	1008.81	n/a
11/11/07	100.00	n/a	n/a	1018.19	n/a
11/12/07	100.00	n/a	n/a	1006.41	n/a
11/13/07	100.00	n/a	n/a	989.69	n/a
11/14/07	100.00	n/a	n/a	985.91	n/a
11/15/07	100.00	n/a	n/a	971.31	n/a
11/16/07	100.00	n/a	n/a	987.69	n/a
11/17/07	100.00	n/a	n/a	1005.41	n/a
11/18/07	100.00	n/a	n/a	1014.69	n/a
11/19/07	100.00	n/a	n/a	1017.31	n/a
11/20/07	100.00	n/a	n/a	999.31	n/a
11/21/07	100.00	n/a	n/a	986.19	n/a
11/22/07	100.00	n/a	n/a	971.41	n/a
11/23/07	100.00	n/a	n/a	1009.00	n/a
11/24/07	100.00	n/a	n/a	1020.19	n/a
11/25/07	100.00	n/a	n/a	1002.81	n/a
11/26/07	100.00	n/a	n/a	985.00	n/a
11/27/07	100.00	n/a	n/a	977.59	n/a
11/28/07	100.00	n/a	n/a	1006.50	n/a
11/29/07	100.00	n/a	n/a	989.00	n/a
11/30/07	100.00	n/a	n/a	1000.41	n/a
Total	100.00	n/a	n/a	29959.91	n/a

Generator Output Power

