

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

03/01/08 to 03/31/08

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	0.4	41.0	47.7
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 1, Brooklyn, NY

03/01/08 to 03/31/08

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
03/01/08	98.96	n/a	n/a	978.91	n/a
03/02/08	100.00	n/a	n/a	1002.38	n/a
03/03/08	56.25	n/a	n/a	554.91	n/a
03/04/08	0.00	n/a	n/a	-	n/a
03/05/08	0.00	n/a	n/a	-	n/a
03/06/08	0.00	n/a	n/a	-	n/a
03/07/08	98.96	n/a	n/a	981.19	n/a
03/08/08	100.00	n/a	n/a	959.00	n/a
03/09/08	100.00	n/a	n/a	996.19	n/a
03/10/08	100.00	n/a	n/a	1001.50	n/a
03/11/08	100.00	n/a	n/a	989.13	n/a
03/12/08	100.00	n/a	n/a	970.88	n/a
03/13/08	100.00	n/a	n/a	982.50	n/a
03/14/08	100.00	n/a	n/a	968.22	n/a
03/15/08	100.00	n/a	n/a	965.28	n/a
03/16/08	100.00	n/a	n/a	977.81	n/a
03/17/08	100.00	n/a	n/a	1003.31	n/a
03/18/08	100.00	n/a	n/a	996.50	n/a
03/19/08	100.00	n/a	n/a	964.28	n/a
03/20/08	100.00	n/a	n/a	959.31	n/a
03/21/08	100.00	n/a	n/a	978.41	n/a
03/22/08	100.00	n/a	n/a	977.09	n/a
03/23/08	100.00	n/a	n/a	985.69	n/a
03/24/08	100.00	n/a	n/a	990.22	n/a
03/25/08	97.92	n/a	n/a	559.09	n/a
03/26/08	94.79	n/a	n/a	0.00	n/a
03/27/08	95.83	n/a	n/a	0.00	n/a
03/28/08	97.92	n/a	n/a	528.31	n/a
03/29/08	100.00	n/a	n/a	1006.91	n/a
03/30/08	100.00	n/a	n/a	1018.19	n/a
03/31/08	100.00	n/a	n/a	998.09	n/a
Total	88.41	n/a	n/a	24293.28	n/a

Generator Output Power

