

## GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 2, Brooklyn, NY

01/01/07 to 12/31/07

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	0.6	61.7	100.3
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

## GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 2, Brooklyn, NY

01/01/07 to 12/31/07

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
Jan 2007	97.21	n/a	n/a	51522.91	n/a
Feb 2007	98.47	n/a	n/a	39607.38	n/a
Mar 2007	95.93	n/a	n/a	40986.81	n/a
Apr 2007	96.42	n/a	n/a	42225.09	n/a
May 2007	84.91	n/a	n/a	34887.66	n/a
Jun 2007	96.46	n/a	n/a	38845.59	n/a
Jul 2007	90.15	n/a	n/a	41686.00	n/a
Aug 2007	27.32	n/a	n/a	14557.09	n/a
Sep 2007	54.62	n/a	n/a	27144.38	n/a
Oct 2007	89.82	n/a	n/a	44760.25	n/a
Nov 2007	99.10	n/a	n/a	44282.88	n/a
Dec 2007	99.63	n/a	n/a	50613.25	n/a
Total	85.72	n/a	n/a	471119.28	n/a

# Generator Output Power

