

## GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 2, Brooklyn, NY

02/01/08 to 02/29/08

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	3.8	68.7	99.3
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

## GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 2, Brooklyn, NY

02/01/08 to 02/29/08

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
02/01/08	100.00	n/a	n/a	1716.00	n/a
02/02/08	100.00	n/a	n/a	1677.50	n/a
02/03/08	100.00	n/a	n/a	1687.00	n/a
02/04/08	100.00	n/a	n/a	1729.25	n/a
02/05/08	100.00	n/a	n/a	1669.31	n/a
02/06/08	100.00	n/a	n/a	1634.81	n/a
02/07/08	0.00	n/a	n/a	-	n/a
02/08/08	98.96	n/a	n/a	1704.00	n/a
02/09/08	100.00	n/a	n/a	1663.44	n/a
02/10/08	100.00	n/a	n/a	1674.19	n/a
02/11/08	100.00	n/a	n/a	1826.50	n/a
02/12/08	100.00	n/a	n/a	1788.38	n/a
02/13/08	100.00	n/a	n/a	1685.00	n/a
02/14/08	100.00	n/a	n/a	1762.44	n/a
02/15/08	100.00	n/a	n/a	1629.88	n/a
02/16/08	100.00	n/a	n/a	1680.19	n/a
02/17/08	100.00	n/a	n/a	1552.69	n/a
02/18/08	100.00	n/a	n/a	1525.25	n/a
02/19/08	100.00	n/a	n/a	1608.69	n/a
02/20/08	100.00	n/a	n/a	1663.06	n/a
02/21/08	100.00	n/a	n/a	1693.25	n/a
02/22/08	100.00	n/a	n/a	1630.19	n/a
02/23/08	100.00	n/a	n/a	1602.06	n/a
02/24/08	100.00	n/a	n/a	1603.31	n/a
02/25/08	100.00	n/a	n/a	1587.00	n/a
02/26/08	97.92	n/a	n/a	1478.13	n/a
02/27/08	77.08	n/a	n/a	1422.75	n/a
02/28/08	100.00	n/a	n/a	1711.50	n/a
02/29/08	0.00	n/a	n/a	-	n/a
Total	92.21	n/a	n/a	44605.75	n/a

# Generator Output Power

