

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 2, Brooklyn, NY

01/01/08 to 12/31/08

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	0.2	63.9	99.3
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 2, Brooklyn, NY

01/01/08 to 12/31/08

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
Jan 2008	21.74	n/a	n/a	11846.81	n/a
Feb 2008	88.79	n/a	n/a	42909.88	n/a
Mar 2008	98.79	n/a	n/a	45667.25	n/a
Apr 2008	92.43	n/a	n/a	44411.38	n/a
May 2008	73.02	n/a	n/a	37905.56	n/a
Jun 2008	100.00	n/a	n/a	47882.63	n/a
Jul 2008	84.41	n/a	n/a	42092.75	n/a
Aug 2008	98.19	n/a	n/a	46662.13	n/a
Sep 2008	92.60	n/a	n/a	40938.75	n/a
Oct 2008	100.00	n/a	n/a	50359.88	n/a
Nov 2008	91.32	n/a	n/a	32495.63	n/a
Dec 2008	99.50	n/a	n/a	47264.50	n/a
Total	86.64	n/a	n/a	490437.13	n/a

Generator Output Power

