

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 2, Brooklyn, NY

04/01/09 to 04/30/09

	Line 1			Line 2			Line 3			Totals		
	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min	Avg	Max
Voltage (V)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current (amps)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
True Power (kW)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	0.0	13.6	115.8
Apparent Power (kVA)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Power Factor (-)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Voltage THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Current THD (%)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Frequency (hz)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

GENERATOR POWER QUALITY - DATA SUMMARY

Sea Rise 2, Brooklyn, NY

04/01/09 to 04/30/09

Date	Good Data (%)	Generator Apparent Power (kVAh)	Generator Reactive Power (kVARh)	Generator True Power (kWh)	Power Factor (-)
04/01/09	50.00	n/a	n/a	0.00	n/a
04/02/09	48.96	n/a	n/a	0.00	n/a
04/03/09	50.00	n/a	n/a	0.00	n/a
04/04/09	47.92	n/a	n/a	0.00	n/a
04/05/09	50.00	n/a	n/a	0.00	n/a
04/06/09	67.71	n/a	n/a	0.00	n/a
04/07/09	86.46	n/a	n/a	0.00	n/a
04/08/09	90.63	n/a	n/a	328.75	n/a
04/09/09	86.46	n/a	n/a	199.63	n/a
04/10/09	88.54	n/a	n/a	56.50	n/a
04/11/09	98.96	n/a	n/a	594.50	n/a
04/12/09	100.00	n/a	n/a	626.13	n/a
04/13/09	83.33	n/a	n/a	201.25	n/a
04/14/09	89.58	n/a	n/a	6.50	n/a
04/15/09	95.83	n/a	n/a	0.00	n/a
04/16/09	86.46	n/a	n/a	2.00	n/a
04/17/09	98.96	n/a	n/a	0.00	n/a
04/18/09	100.00	n/a	n/a	0.00	n/a
04/19/09	100.00	n/a	n/a	0.00	n/a
04/20/09	92.71	n/a	n/a	0.00	n/a
04/21/09	97.92	n/a	n/a	3.50	n/a
04/22/09	96.88	n/a	n/a	0.00	n/a
04/23/09	100.00	n/a	n/a	0.00	n/a
04/24/09	98.96	n/a	n/a	0.00	n/a
04/25/09	98.96	n/a	n/a	0.00	n/a
04/26/09	100.00	n/a	n/a	0.00	n/a
04/27/09	94.79	n/a	n/a	0.00	n/a
04/28/09	97.92	n/a	n/a	0.00	n/a
04/29/09	76.04	n/a	n/a	13.25	n/a
04/30/09	84.38	n/a	n/a	0.00	n/a
Total	85.28	n/a	n/a	2032.00	n/a

Generator Output Power

